

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE J		PAGE OF PAGES 1 4	
2. AMENDMENT/MODIFICATION NO. 0004		3. EFFECTIVE DATE 22-Mar-2011		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)	
6. ISSUED BY USACE, KANSAS CITY FEDERAL BUILDING CT-M, 601 E 12TH STREET KANSAS CITY MO 64106-2896		CODE W912DQ		7. ADMINISTERED BY (If other than item 6) See Item 6		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				<input checked="" type="checkbox"/> X		9A. AMENDMENT OF SOLICITATION NO. W912DQ-11-R-4014	
				<input checked="" type="checkbox"/> X		9B. DATED (SEE ITEM 11) 24-Feb-2011	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>5</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) See continuation page for the purpose of this amendment.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)				BY _____ (Signature of Contracting Officer)		22-Mar-2011	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGESAMENDMENT 0004

The SOLICITATION is amended as follows:

NOTE: Deleted text is shown with strikethrough. Added text is shown with underline.

1. SPECIFICATIONS:

MP School

Section 01010 SCOPE OF WORK, Paragraph 4.11 ROAD NETWORK, SITE WORK, AND PARKING is changed to read as follows:

The Contractor shall construct the entire road and parking network, as shown on the drawings. The Contractor shall be responsible to construct all site work shown on the attached construction drawings and meet the requirements of the customer. A storm drainage system, consisting of concrete lined ditches, shall also be constructed with the road network. The road layout shall provide access to ECP, parking lots, vehicle maintenance facilities, fuel points and trash collection points. The Contractor shall coordinate as necessary with adjacent contractors to provide connection between existing and proposed road networks. The Contractor shall provide a smooth transition between existing and proposed roadways. The Contractor shall also construct a driving course, consisting of aggregate and asphalt roadways. Roadways and walkways are required and shall be constructed based upon recommendations from geotechnical analysis as required herein. Aggregate walkways are required to connect all buildings, facilities, site features, and parking lots. The Contractor shall also construct an outdoor assembly area (parade ground area) and two volleyball courts.

~~The Contractor shall provide landscaping for the compound. The extent of landscaping shall be coordinated with the Contracting Officer.~~ Provide a network of aggregate walkways to connect the buildings. Walkways shall be wide enough to be used as fire-lane/ service roads.

MP School

Section, 01010 SCOPE OF WORK, Paragraph 4.12 GENERAL REQUIREMENTS FOR FACILITIES

Removal of text in Table: CAMP SHAHEEN MP School - 11-N002, SITE ADAPT FACILITIES,

Column "Size(sm)," Row "Parade Field, Remove "4800." Refer to Civil for size.

CAMP SHAHEEN MP School - 11-N002		Site Identifier	Standard Identifier	Standard Date	Structure	Size (sm)
SITE ADAPT STANDARD BUILDINGS						
Entry Control Point Facilities						
	ECP Canopy	171	FP01	30-Sep-09	Metal	98.4
	ECP Guard Shack	170	FP05	30-Sep-09	CMU	12
Personnel Bunkers						
	Bunkers	-	FP06	23-Feb-10	Concrete	25 PN ea.
Trash Collection Point						
	Trash Point	-	G01	23-Feb-10	Concrete	3.24
Trash Collection Point						
	Parade Field	105	G02	23-Feb-10	Open	4800
	Troop Review Stand	106		23-Feb-10	Concrete	119
Small Arms Storage						
	Small Arms Maint./Storage	130	S03	23-Feb-10	CMU	98
	Small Arms Maint./Storage	150	S03	23-Feb-10	CMU	98
POL Building						
	Petroleum, Oil, Lubricant	133	S05	23-Feb-10	CMU	25
Vehicle Refueling Point						
	Fuel Stor. & Vehicle Refueling Pt	109	VM03	23-Feb-10	Concrete	
Fuel Operations Building						
	Fuel Operations Building	109	VM04	23-Feb-10	Concrete	9
Wash Rack						
	Wash Rack	109	VM08	23-Feb-10	Open	145.86

MP School

Section, 01015, paragraph, 5.21.4 GENERATOR FUEL STORAGE/DISTRIBUTION, is changed to read as follows:

Provide above-ground, horizontal storage tanks within a concrete containment dike. Provide 30-day storage capacity for ~~prime-duty plants-generators~~. Storage tank volume shall be based on the rate of fuel consumption of all engines including spares, at 100 percent load, multiplied by a 0.75 operating factor. Tanks shall be factory fabricated and shall be of the manufacturer standard sizes.

Signal School

Section 01010 SCOPE OF WORK, Paragraph 4.12 ROAD NETWORK, WALKWAY, AND PARKING is changed to read as follows:

~~Roads, parking and storage areas shall be of aggregate surface.~~ The Contractor shall construct the entire road and parking network. A storm drainage system shall also be constructed. The road layout shall provide access to parking lots, vehicle maintenance facilities, and the trash collection points as well as coordinating proper connections to adjacent construction activities located at the MP/PST School. Roadways and walkways are required and shall be constructed based upon recommendations from geotechnical analysis as required herein. Aggregate walkways are required to connect all buildings, facilities, site features and parking lots. The Contractor shall also construct an outdoor assembly area (parade ground) and two volleyball courts.

~~The Contractor shall provide landscaping for the compound.~~ Provide a network of aggregate walkways to connect the buildings. Walkways shall be wide enough to be used as fire-lane/ service roads.

2. DRAWINGS:

The following drawings are reissued. A copy of the reissued drawings accompanies this amendment.

MP_CP501
MPS_SE101
MPS_ES102
SS_CP101
SS_CP501
SS_SE101
SS_TS100
SS_TS101
RP_101
RP_501

(End of Summary of Changes)